

**ADDENDUM NUMBER TWO
TO
WW046 WWTP ULTRAVIOLET DISINFECTION REPLACEMENT
FORT CAMPBELL, KENTUCKY**

Addendum Number Two (2) is issued the 16th day of June 2025 to all parties who hold a set of Bid Documents for the above-named project. Each Bidder shall acknowledge receipt of this Addendum on the Bid and shall incorporate all changes in the Bid. This addendum consists of one (1) page.

MODIFICATIONS:

SPECIFICATIONS

The following specification section modifications are hereby made a part of the above referenced Project Contract Documents:

SECTION 44 44 73 UV DISINFECTION EQUIPMNET FOR WASTEWATER

- Paragraph 1.09.A.3 – Delete UV Transmittance Sensor (One) from the list of spare parts.
- Paragraph 2.03.C.2. Replace “fecal coliform” with “e. Coli”.
- Paragraph 2.05.F.5.a. Replace the word “Lamp” with “Bank”.
- Paragraph 2.05.G.3. Replace the 2nd sentence in this paragraph with the following – Media converter shall be Phoenix Contact MC 1000-MM LC (PN: 1329819), Key features : Copper Port : RJ-45, Ethernet; Fiber Optic Port: LC Duplex, Multi-Mode.
- Paragraph 3.04.C.13.e. Replace “fecal coliform” with “e. Coli”.

This Addendum Number Two (2) is issued this the 16th day of June 2025.

Ben Simerl, P.E.

Jacobs

2095 Lakeside Centre Way, Suite 200
Knoxville, Tennessee 37922
ben.simerl@jacobs.com

